



INDIAN INSTITUTE
OF TECHNOLOGY
PALAKKAD

Indian Institute of Technology Palakkad

भारतीयप्रौद्योगिकीसंस्थानपालक्काड

STORES & PURCHASE SECTION

Email: purchase@iitpkd.ac.in

Telephone: 04923-226586/87

GSTIN: 32AAAAI9910J1ZR

Tender No. TENDER/2023-24/438

Date of Publication: 04-01-2024

Date/Time of Closing: 25-01-2024, 15:00 hours

Indian Institute of Technology Palakkad Invites Tender under Two-bid system for the:

**SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF
SQUID MAGNETOMETER WITH CLOSED-CYCLE 4HE CRYOSTAT AND SUPERCONDUCTING MAGNET**

Conforming to the specifications as in BoQ Technical.

Tender Documents may be downloaded from the e-Wizard Portal <https://mhrd.euniwizarde.com/>. Aspiring Bidders who have not enrolled / registered in e-Wizard should enroll / register before participating through the website <https://mhrd.euniwizarde.com/>. Bidders are advised to go through instructions provided at “**Procedure for Submission of E-tender**”. [Special Instructions to the Contractors/Bidders for the e-submission of the bids online through this e-Wizard Portal”].

Bidders can access tender documents on the website. For searching in the site, kindly go to Live Tenders option, Click “Advance Search” and select Department as ‘IIT Palakkad’. Thereafter, Click on “Search” button to view all IIT Palakkad tenders. Select the appropriate tender and fill them with all relevant information and submit the completed tender document online on the website <https://mhrd.euniwizarde.com/> as per the timeline below.

No manual bids will be accepted. All tender documents including Techno-Commercial, Technical and Financial bids should be submitted in the e-Wizard portal.

S. No.	Events	Date and Time
1	Publication of the Tender Document	04-01-2024
2	Date of Pre-Bid Meeting	16-01-2024, 11:00 hours
3	Last Date/Time for submission of ONLINE Bids	25-01-2024, 15:00 hours
4	Opening of Technical Bids	25-01-2024, 15:15 hours

Pre-Bid Meeting:

- Online Pre-Bid meeting will be held on **16-01-2024 at 11:00 AM** to clear the doubts of intending bidders. The details of the meeting will be intimated through ONLINE Portal. Bidders, who are unable to attend the Pre-Bid meeting, may send their queries for the same, latest by 12-01-2024, 15:00 hours to purchase@iitpkd.ac.in.
- Queries received after the Pre-Bid Meeting shall not be considered. Addendum/ Corrigendum/ Clarifications to the queries will be uploaded, paused the Pre-Bid meeting in the online portal, which shall be the part of the tender document.

TERMS AND CONDITIONS

1	GENERAL	<ul style="list-style-type: none">(a) The responsibility of submission of the bids on or before the last date shall rest with the tenderer. The institute will hold no responsibility for the non-receipt of the bids or the bids received after the date/time specified. Any bid received by IITPKD after the bid submission deadline prescribed by IITPKD, shall be rejected and returned unopened to the Bidder.(b) Canvassing or offer of an advantage or any other inducement by any person with a view to influencing acceptance of a bid is an offence under the Laws of India. Such action will result in the rejection of bid, in addition to other punitive measures.(c) Each bidder shall submit only one bid, either by himself or as a partner in a joint venture or as a member of the consortium. If a bidder or if any of the partners in a joint venture or any one of the members of the consortium participate in more than one bid, the bids (of both the individual and the partnership/consortium/joint venture) are liable to be rejected.(d) The bidder shall bear all costs associated with the preparation and submission of his bid and IITPKD shall in no case be responsible or liable for those costs, regardless of the conduct or outcome of the tender process.(e) IITPKD will respond to any request for clarification or modification of the Tender Document that are received up to TWO DAYS prior to the deadline for submission of bids prescribed by IITPKD. For this purpose, the prospective bidder(s) requiring clarification in the Tender Document shall notify IITPKD through the ONLINE Portal ONLY. Any such clarification, together with all the details on which the clarification had been sought, will be published in the ONLINE Portal ONLY. Deviations, if any, observed by the Institute in the submitted bids, from the Terms and Conditions of the Tender Document will not be accepted by the Institute.(f) Except for any such clarification by the Institute, which is expressly stated to be an addendum to the tender document issued by the Registrar, IIT Palakkad, no written or oral communication, presentation or explanation by any other employee of any of the Sections/Departments of the Institute, shall be taken to bind or fetter the Institute.(g) The bidder is expected to examine all instructions, forms, terms and conditions in the Tender Document. In the event of discovery of any missing pages, the bidder shall inform the same to the Section/ Department concerned. Failure to furnish the information required by the Tender Document or submission of a tender not substantially responsive to the Tender Document in every respect will be at the bidder's risk and may result in rejection of the bid.(h) The bidder shall not make or cause to be made any alteration, erasure or obliteration to the text of the Tender Document.(i) The Supplier shall not, without the prior written consent of the IITPKD, assign to any third party, the Contract or any part thereof.
2	COMPOSITION OF THE TENDER DOCUMENT	<ul style="list-style-type: none">(a) The Tender Document comprises of:<ul style="list-style-type: none">Instruction to the bidders including terms and conditions1. Technical Specifications (Annexure-I)2. Undertaking by the Bidder (Annexure-II)3. Fall Clause Notice Certificate (Annexure-III)4. Annexure regarding Blacklisting/Debarment (Annexure-IV)5. Self Declaration – MII Order (Annexure-V)

3	DOCUMENTS COMPRISING THE BID	<p>(a) The Technical, Techno-commercial and Commercial Bids (Cover One) and Commercial Bid (Cover Two) shall be submitted ONLINE through the e-Wizard Portal.</p> <p>(b) Bids submitted in any mode other than ONLINE will be rejected outright.</p> <p>(c) Documents establishing the conformity of the terms and conditions of the Tender Document shall be provided along with the bid. The offer/bids should be sent only for a system or that is available in the market and supplied to a number of customers. A list of customers in India and abroad with details must accompany the quotations. Quotations for a prototype machine will not be accepted.</p> <p>(d) Original catalogue (not any photocopy) of the quoted model duly signed by the principals must accompany the quotation in the Technical bid. No prices should ever be included in the Technical bid.</p> <p>(e) Compliance or Confirmation report with reference to the specifications and other terms and conditions should also be obtained from the principal.</p> <p>(f) Information related to the agency/bidder such as photocopies of the Registration/PAN/GST/TIN shall be furnished.</p> <p>(g) The technical bid should consist of all technical details along with commercial terms and conditions. No prices should be included in the technical bid. Mentioning of Prices in the Technical Bid shall lead to DISQUALIFICATION.</p> <p>(h) Bidders who are bidding for this tender,</p> <ol style="list-style-type: none"> 1) Should have implemented at least TWO ORDERS of SQUID Magnetometer with closed-cycle 4He Cryostat and Superconducting Magnet during previous three financial years (2020-21, 2021-22, 2022-23) from Centrally Funded Technical Institutes (IITs, NITs, IISc, IISER), DRDO, ISRO, CSIR labs or Government Firms in India. Copies of the most recent purchase orders and user certificates of successful implementation must be included. Copies of financial statements or evidence of turnover must be furnished. 2) Should have an Average Annual Turnover of Rs 11,00,00,000/- (RUPEES ELEVEN CRORE ONLY) during the last THREE financial years (2020-21, 2021-22, 2022-23). The bidder shall enclose the audited statements of the indicated financial years, which should have been certified by a Chartered Accountant or a Competent Authority. 3) Should submit Digitally signed Tender Document in Cover One.
4	EARNEST MONEY DEPOSIT (EMD)	<p>(a) The bidder shall furnish EMD of Rs. 11,00,000/- (Rupees Eleven Lakh Only) through online payment gateway in the E-Wizard.</p> <p>(b) Bids not accompanied by EMD shall be DISQUALIFIED.</p> <p>(c) The firms who are registered with National Small Industries Corporation (NSIC) / or Small Scale Industrial (SSI)/ Micro & Small Enterprises (MSEs) are exempted from submitting the EMD. NSIC / MSME registered bidders must submit a copy of a valid NSIC / MSME Registration Certificate for exemption of EMD. It will be applicable for those bidders who shall produce their own goods or provide their own services, and not applicable for trading purposes.</p>
5	PERFORMANCE SECURITY	<p>(a) The performance security shall be submitted within FIFTEEN DAYS of receipt of the material by the IITPKD. The successful bidder shall furnish the Performance Security equal to 5% of the order / contract value (excluding the value of annual maintenance charges). The Performance Security shall be valid all along the warranty period and shall extend up to SIXTY DAYS after the date of completion of warranty period. It shall be ensured by the successful bidder that the validity of the Performance Security submitted is extended depending on the date of commencement of the Warranty.</p>

		<p>(b) The performance security shall be a bank guarantee/E-Bank Guarantee (in the format as provided) issued by the Indian Scheduled bank acceptable to the IITPKD or a Demand Draft favoring, INDIAN INSTITUTE OF TECHNOLOGY PALAKKAD payable at PALAKKAD.</p> <p>(c) The performance security shall automatically become null and void once all the obligations of the Supplier under the Contract have been fulfilled, including, but not limited to, any obligations during the Warranty Period and any extensions to the period. The performance security shall be returned to the Supplier not later than fifteen (15) days after its expiration.</p> <p>(d) Failure of the successful Bidder to comply with the requirements shall constitute enough grounds for the annulment of the award and forfeiture of the EMD, in which event the IITPKD may make the award to the next lowest evaluated bid submitted by a qualified Bidder or call for new bids.</p>
6	<p>BID PRICES AND CURRENCY</p>	<p>(a) Prices must be quoted separately for each equipment/item identified.</p> <p>(b) Price quoted for equipment/items shall include all the costs associated with packing, local transportation from the point of clearance to IITPKD, insurance, loading, unloading and associated delivery charges. The delivery shall be on DOOR DELIVERY basis to the institute including its installation, commissioning, integration and validation. It is the sole responsibility of the supplier to ensure that the equipment is delivered on DDP mode to IIT Palakkad. An undertaking to this effect as in Annexure-II.</p> <p>(c) Prices quoted by the bidder shall be fixed during the validity of the bid.</p> <p>(d) Prices of the equipment/items shall be quoted in Indian Rupees (INR) / Foreign Currency.</p>
7	<p>LETTER OF CREDIT</p>	<p>(a) Upon the successful Bidder's furnishing of the copy of the Purchase Order duly signed on each page and the Performance Security, for the equipment ordered in foreign currency, IITPKD will open a letter of credit (LC) in a convenient Nationalized Bank in India. For opening of LC necessary information shall be provided by the supplier or its authorized agents.</p> <p>(b) In case the successful bidder is a foreign company and wishes to submit Performance Security in the form of Bank Guarantee, the Bank Guarantee should be routed through the Beneficiary Bank to the end user bank. Otherwise, the Indian Agent of the foreign vendor shall submit a Bank Guarantee from a Nationalized Bank of India. The following documents shall be submitted in case of an Indian agent submitting the Performance Security on behalf of his principal:</p> <ul style="list-style-type: none"> • Foreign principal's proforma invoice indicating the commission payable to the Indian agent and nature of after-sales service to be rendered by the Indian agent. • Copy of the agency agreement with the foreign principal and the precise relationship between them and their mutual interest in the business. <p>(c) For imported equipment, a Letter of Credit (LC) shall be opened for 100% CIP price on receipt of the acknowledgment of the purchase order. However, 80% of the LC amount only shall be released on proof of the shipment of the consignment with necessary documents to be provided in detail at the time of placing of the purchase order. Balance 20% of the LC amount shall be released upon the receipt of a performance security of 5% of the total value of the purchase order and installation, commissioning, integration, validation and installation report/certification jointly given by the end user and the supplier.</p>

		<p>Any costs associated with the amendments made in the LC as per the request made by the Supplier s should be borne by the supplier.</p> <p>Any fluctuation in rates / rate conversions arising due to the amendment requests made by the supplier shall be on the supplier and not on the institute.</p>
8	PERIOD OF VALIDITY OF BIDS	<p>(d) Bids shall remain valid for a period of 180 DAYS after the date of the deadline for submission of bids prescribed by IITPKD.</p> <p>(e) If the deadline is extended due to unforeseen circumstances, the bid validity shall be deemed to have extended accordingly.</p>
9	TIME FOR SUPPLY, INSTALLATION, COMMISSIONING AND VALIDATION OF THE EQUIPMENTS/ITEMS	<p>(a) The Supplier shall supply the equipment/items within the period specified in the tender document i.e. within 52 WEEKS of signing the purchase order or within the period mutually agreed between IITPKD and supplier. All the equipment and accessories should be delivered at IIT Palakkad, Sahyadri Campus, Kanjikode, Palakkad-678623, Kerala.</p> <p>(b) The Supplier shall thereafter proceed with the installation, commissioning, integration and validation and demonstrate operational acceptance of the equipment/items within the period specified. The equipment/items shall be installed and commissioned by the successful bidder within 20 to 25 days from the date of its receipt.</p> <p>(c) The tenderer should indicate clearly the time required for delivery of the item. In case there is any deviation in the delivery schedule, liquidated damages clause will be enforced or penalty for the delayed supply period will be levied.</p> <p>(d) In the event of failure of supply of the item/equipment/items within the stipulated delivery schedule, IITPKD has all the right to purchase the item/equipment/items from other sources on the total risk of the Supplier under the risk purchase clause.</p>
10	PRODUCT UPGRADES	The Supplier shall continue to support and maintain the version/model of the Equipment supplied by upgrading the software and the hardware as and when amendments are carried out in the existing version or the product is upgraded. Whereas upgrades to the software shall be supplied free of cost, the Supplier may charge for upgrade in hardware provided it is of major nature. An upgraded higher version of the instrument and software related with the instrument shall be supplied.
11	PENALTIES	If the Supplier fails to complete any of the activities in accordance with the time specified for it, or any extension of time granted by IITPKD, Liquidated Damages Clause shall be invoked.
12	UP-TIME GUARANTEE/ DOWNTIME PENALTY CLAUSE	<p>(a) The Supplier should provide up-time guarantee of 95% [24 (hours) X 7 (days) X 365 (days)] basis during the warranty period.</p> <p>(b) The Supplier should provide up-time guarantee of 95% (24 hours/day basis) both during warranty. If downtime exceeds the 5% limit, extension of the warranty period will be twice the excess down time period.</p>
13	LIQUIDATED DAMAGES	If a firm accepts an order and fails to execute the order, in full or part, as per the terms and conditions stipulated therein, it will be open to the Institute to recover liquidated damages from the firm at the rate of 1% of the value of the undelivered goods per month or part thereof, subject to a maximum of 5% of the value of the undelivered goods. It will also be open to the Institute alternatively, to arrange procurement of the required stores from any source, at the risk and expense of the firm, accepted and failed to execute the order according to stipulations agreed upon. This will also entail the removal of the defaulters' name from the approved/registered list of Suppliers.
14	EFFECT OF FORCE MAJEURE	(a) If the Supplier is prevented, hindered, or delayed from or in performing any of its obligations under the Contract by an event of Force Majeure, then it shall notify the IITPKD in writing of the occurrence of such event and the circumstances of the event of Force Majeure within FIFTEEN DAYS after the occurrence of such event.

		<p>(b) The Supplier, when affected by the event of Force Majeure shall use reasonable efforts to mitigate the effect of the event of Force Majeure upon its performance of the Contract and to fulfill its obligations under the Contract, but without prejudice to IITPKD's right to terminate the Contract.</p> <p>(c) No delay or non-performance by the Supplier caused by the occurrence of any event of Force Majeure shall:</p> <ol style="list-style-type: none"> i. Constitute a default or breach of the Contract; ii. Give rise to any claim for damages or additional cost or expense occasioned by the delay or non-performance. <p>(d) If the performance of the Contract is substantially prevented, hindered, or delayed for a single period of more than THIRTY DAYS or an aggregate period of more than SIXTY DAYS on account of one or more events of Force Majeure, the IITPKD shall have the right to terminate the Contract by giving a notice to the Supplier.</p>
15	EXTENSION OF TIME LIMITS FOR SUPPLY AND MAKING OPERATIONAL, THE EQUIPMENT	<p>(a) The time limit for supply, installation & commissioning, integration & validation shall be extended if the supply is delayed or impeded in the performance of any of its obligations under the Contract by reason of any of the following:</p> <ol style="list-style-type: none"> i. Any occurrence of Force Majeure; ii. Any other matter specifically mentioned in the Contract; <p>(b) By such period as shall be fair and reasonable in all the circumstances and as shall fairly reflect the delay or impediment sustained by the Supplier.</p>
16	GOVERNING LAW AND SETTLEMENT OF DISPUTES	<p>(a) The Contract shall be governed by and interpreted in accordance with the laws of India.</p> <p>(b) Any dispute or claim arising out of/relating to this Contract of the breach, termination or the invalidity thereof, shall be settled by the Hon'ble Courts of Justice at Palakkad.</p> <p>(c) The page number should be marked in all pages serially (including all supporting documents enclosed with the tender document) and the declaration for the same shall be submitted by the bidder as in Annexure-II.</p> <p>(d) IITPKD reserves the right to accept or reject any or all the tenders in part or whole or may cancel the tender at its sole discretion without assigning any reason whatsoever. No further correspondence in this regard will be entertained.</p>

AWARD OF CONTRACT

1	AWARD CRITERIA	<ol style="list-style-type: none">1. IITPKD will award the Contract to the Bidder whose bid has been determined to be substantially responsive and as per the Order No. P-45021/2/2017-PP(BE-II) dated 16-09-2020 from Department for Promotion of Industry and Internal Trade (Public Procurement Section), Ministry of Commerce and Industry, Govt. of India.2. The Institute reserves the right to buy different items/quantities from different bidders considering price of individual/group of equipment/items or any other factors as decided by the Committee.
2	AWARD OF PURCHASE ORDER	<ol style="list-style-type: none">1. Prior to the expiration of the period of bid validity, IITPKD will issue the Letter of Intent / Purchase Order to the successful Bidder in writing.2. Any amendment(s) in the Purchase Order will be permitted within SEVEN DAYS of its issuance. No amendments will be permitted beyond this period.3. The Purchase Order will constitute the foundation of the Contract.
3	CONTRACT AGREEMENT	<ol style="list-style-type: none">1. Within SEVEN DAYS of receipt of the Purchase Order, the successful Bidder shall sign and date its copy on each page and return it to the Purchaser.2. Copy of Purchase Order duly signed and dated by the successful Bidder on each page shall constitute the Contract Agreement.
4	CONTRACT DOCUMENTS / AMENDMENT TO CONTRACT	<ol style="list-style-type: none">1. All documents forming part of the Contract (and all parts of these documents) are intended to be correlative, complementary and mutually explanatory. The Contract shall be read as a whole.2. The order of precedence of the Contract documents shall be as follows:<ol style="list-style-type: none">(i) Contract Agreement/Purchase Order(ii) All Forms/Annexures(iii) equipment/items and their requirement(iv) Supplier's Bid(v) Tender Document3. No amendment or other variation of the Contract shall be effective unless it is in writing, is dated, expressly refers to the Contract and is signed by a duly authorized representative of each party to the Contract.

REGISTRAR

Name of the Item :	SQUID Magnetometer with closed-cycle ⁴ He Cryostat and Superconducting Magnet
Quantity:	1
Warranty Period:	3 years onsite warranty on all components

TECHNICAL SPECIFICATIONS

S. No	Items	IIt PKD required Specification
1	Equipment Name	SQUID Magnetometer with closed-cycle ⁴ He Cryostat and Superconducting Magnet
2	Purpose and Basic Features	<p>Fully Automated computer controlled cryogen-free magnetometer with re-condensing/re-liquefier ⁴He system, superconducting magnet and Superconducting Quantum Interference Device (SQUID) coil.</p> <p>Temperature and magnetic field dependent dc magnetization and ac susceptibility (χ' and χ'') through automated program</p> <p>Capability of measuring single crystalline, polycrystalline powder, thin film samples.</p> <p>Excellent temperature and magnetic field stability.</p> <p>Fast cool down using minimum volume of ⁴He gas and minimum consumption of ⁴He gas during measurement.</p>
3	Cryostat Specification	<p>The system must be cooled down to 1.8 K using ⁴He gas, Cryocooler consisting of Compressor and Chiller without any cryogenic liquid. <u>Vendor must provide cryocooler details and required chiller details.</u></p> <p>Initial cool down (from room temperature and from fully warmed up condition) time should be below 72 hours. <u>Log data has to be provided from a system installed in INDIA.</u></p> <p>Required ⁴He gas cylinder for initial cooldown must be specified. Preferably below 3 Nos. of 47 L ⁴He gas cylinder.</p> <p>The maximum quantity of liquid helium collected through condensation of the helium gas should be preferably ≤ 20 liters when the system is operating at its full capacity in order to ensure minimum, ⁴He loss during a breakdown/warm-up. The liquid ⁴He Dewar size should be below 25 liters. Vendor must mention the liquid ⁴He reservoir volume.</p> <p>Usage of ⁴He gas during continuous operation (without full warm up) should be minimum. Preferably one 47 L Cylinder in 3 months for rigorous usage. Vendor must provide a suitable number which can be verified from a user in INDIA.</p> <p>Cooldown should be automated through the program. The program should indicate status of liquid in reservoir and gas in the connected cylinder. A warning for cylinder change is preferred.</p>
4	Magnetic Control Specification	<p>Superconducting magnet with longitudinal field of +7 Tesla to -7 Tesla.</p> <p>Field uniformity better than +/- 0.01% over 4 cm.</p> <p>Remnant field 7 Oe or less when zero field is set. Supporting data will be asked during technical evaluation</p> <p>Magnet Controller should have linear, no over-shoot, oscillatory and sweep modes for field setting.</p> <p>Maximum field sweep rate: 200 Oe/sec, minimum field sweep rate for measurement : 5 Oe/sec. Log file from an INDIAN user will be asked during technical evaluation.</p>

5	Temperature Control Specification	Temperature range for all measurement should be 1.8 K to 400K or better with good temperature stability better than 0.5%. For temperature stability log file has to be provided for magnetic field sweep -7 to + 7 Tesla, all five quadrant at 2 K and 5 K.
		Temperature sensitivity 10 mK
		Temperature control at all range should be automatic through program and it should be smooth. M vs. T measurement data in temperature sweep mode shall be provided to support the claim.
		Temperature accuracy should be proven with superconducting transition of Tin and Lead.
6	DC Magnetization Measurement	It should be measured by DC mode/VSM mode (using SQUID coil)/ linear motor mode (using SQUID coil). Vendor must provide technical details of the quoted mode. Only one mode shall be quoted.
		Sensitivity: 6×10^{-7} emu at high field or better. <u>Vendor must provide supporting data with log data files.</u>
		Maximum DC moment: 2 emu
		The noise level should be below 5% for low moment (for 10^{-4} emu or lower) and below 1% for high moment (for 0.001 emu or higher)
		The time for M vs. T measurement with 100 data points between 1.8 K to 350 K should be below 5 hours. Supporting data with log file shall be provided.
		The time for M vs H measurement time with 500 data points between +7 Tesla to -7 Tesla at 5 K should be below 6 hours (in field sweep mode). <u>Supporting data with log file shall be provided.</u>
		Vendor shall provide proof of 10 publications with the quoted mode of magnetization measurement in last five years.
7	Accessory:AC Susceptibility Measurement	AC susceptibility measurement option should be quoted as an accessory.
		Ac susceptibility (both χ' and χ'') shall be measured using the option in the frequency range 0.1 Hz to 500 Hz in the temperature range 1.8 K to 400 K
		Sensitivity : 1×10^{-7} emu or better.
		Peak amplitude: 0.1 Oe – 10 Oe
		The option should measure χ' vs. T and χ'' vs. T at different field and different frequency. The measurement program should easily be set using the computer.
		The ac susceptibility measurement option shall be accessible without changing any hardware option such that the measurement can be done without taking out the sample.
8	Data Acquisition	Suitable PC on a strong base/table. Original OS and antivirus should be provided.
		A user friendly data acquisition software/ program should be provided. The program should log data and raw files for each data point. The data file should be available in multicolumn .dat format.
		The software should have capability to execute a long MT, MH measurement sequence for at least 48 hours without human intervention
		During the measurement a window should show live plot of the measured data.
		The program should demonstrate all the suitable warning for easy troubleshooting.
		The program should be accessible via teamviewer.
9	Power requirement	Single or Three phase Indian power supply. The exact power

		requirement must be specified. If dual powers supply option available for compressor, the user may specify the same.
10	Future Upgrade	<p>Ultra low field measurement.</p> <p>High temperature dc magnetization measurement (300 K - 1000 K)</p> <p>DC mode, VSM mode/Linear motor mode (If quoted with the other option)</p> <p>DC magnetization under transverse and/or longitudinal rotation in field</p> <p>DC magnetization measurement in Hydrostatic pressure cell</p> <p>DC and AC magnetization measurement down to 400 mK.</p>
11	Warranty	3 years onsite warranty on all components.
12	Essential Accessories and Information	<p>Different sample holders for crystals, powder, thin film.</p> <p>Measurement straw with low (below 10^{-6} emu) background moment : 1000 pcs.</p> <p>Standard samples</p> <p>Suitable UPS. If not quoted, requirement must be provided.</p> <p>Suitable Chiller. If not quoted, requirement must be provided.</p> <p>Long cables and cryotubes for distancing the compressor and cryostat.</p> <p>Any consumable required for the complete installation and functioning of the system to its full capability on site should be included (like o-rings, glue for sample holder etc.)</p> <p>Info: Floor mapping of the equipment with all its components.</p> <p>Info: Size of the packing boxes.</p> <p>Info: Maximum Weight/sq. Ft.</p>
13	Technical evaluation requirement	<p>All the log files and measurement data will be asked from a chosen facility in any CFTI in INDIA during the technical evaluation process. The data has to be provided within two weeks after providing samples. Contact details of the INDIAN facility should be provided along with the technical bid. IIT Palakkad may send samples to the chosen facility for reproduction of already measured data.</p> <p>Following data (for all measurement log file also needed) and log file has to be provided to prove the quoted specifications:</p> <ol style="list-style-type: none"> 3. FC and ZFC M vs. T data for Indium. 4. M vs. T for a magnetic sample in T-sweep and stable mode. 5. M vs. H data +7 to – 7 Tesla for all five quadrant below and above transition temperature in field sweep mode. 6. Log file for fastest heating up 1.8 K to 400 K and fastest cooling down 400 K to 1.8 K. 7. Field sweep log file in maximum sweep rate and minimum sweep rate. <p>Proof of similar system installed in INDIA along with contact details.</p> <p>Proof of at least 10 publications in last five years produced using the quoted system.</p>
14	Equipment Acceptance Criteria	<ol style="list-style-type: none"> (e) Initial Cooldown criteria. (f) Field and temperature stability and sweep rate. (g) M vs T and M vs H committed measurement time. (h) M vs T and M vs H on five different types of samples. (i) Data with acceptable noise level for low moment systems. (j) Extensive training to at least two technical staffs and 4-5 PhD students and 2 faculties.
15	Delivery time	4. Delivery and installation must be completed within 12 months of PO.

UNDERTAKING BY THE BIDDER
(TO BE SUBMITTED ONLY THROUGH ONLINE MODE IN APPROPRIATE FORMAT)

We hereby accept all the Terms and Conditions of the Tender Document and strictly adhere to the same in the event of getting Purchase order. We also declare that the Technical and Financial Bids submitted by us has NO DEVIATION from the Tender Terms and Conditions.

We hereby accept that the PRICES OF THE EQUIPMENTS/ITEMS QUOTED ARE AS PER THE INCOTERMS 2022 - DDP MODE, IIT PALAKKAD AND CLAUSE NO.6 OF THE TENDER DOCUMENT.

We hereby undertake that there are _____ pages, serially numbered, in the submitted tender including the supporting documents. (Please serially number all the pages including blank page, if any).

We have submitted our principal's exclusive authorization letter which is specific for this tender No. _____ dated _____.

Note: This letter should be on the letterhead of the quoting firm and should be signed by a Competent Authority.

ANNEXURE-III

FALL CLAUSE NOTICE CERTIFICATE
(TO BE SUBMITTED ONLY THROUGH ONLINE MODE IN APPROPRIATE FORMAT)

This is to certify that we have offered the maximum possible discount to you in our Quotation No. _____ dated _____ **(Please do not reveal the prices here, which will lead to outright rejection of your bid).**

The prices charged for the Stores supplied under tender should under no event be higher than the lowest prices at which the party sells the items of identical description to any other Govt. organization/PSU's/Central Govt., /State Govt. Autonomous bodies/Central/state Universities/Central/State Educational Institutions, failing which the "FALL CLAUSE" will be applicable. The institute will look into a reasonable past period to ensure this.

In case, if the price charged by our firm is found to be more, **IIT Palakkad** will have the right to recover the excess charged amount from the subsequent/unpaid bill of the supplier.

Note: This letter of authority should be on the letterhead of the quoting firm and should be signed by a Competent Authority and having the power of attorney.

ANNEXURE-IV

UNDERTAKING REGARDING BLACKLISTING / NON – DEBARMENT

Tender No. _____

To,
M/s. Indian Institute of Technology Palakkad
Ahalia Integrated Campus, Kozhipara,
Palakkad, Kerala 678623

We hereby confirm and declare that we, M/s _____ are not blacklisted/ De-registered / debarred by any Government department/ Public Sector Undertaking/ Private Sector/ or any other agency for which we have Executed/ Undertaken the works/ Services.

For
Company Name and Seal
Authorised Signatory

Note: This letter should be on the letterhead of the quoting firm and should be signed by a Competent Authority.